

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 895

Dated: 30-01-2026

It is certified that an inspection team headed by Chudamani Kalele.....

(Name of Officers with designation) from Chief Chemist, S.R.L. PHED Bhopal

inspected the MITHI GOBINDRAM PUBLIC SCHOOL, Sant Hirdaram Nagar, Bhopal 462030

(Name & Address of the school) on 28-01-2026..(date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 895/S.R.L./P.H.E.D./B.P.L./2026 dated 30-01-2026

of State Research Laboratory, P.H.E.D. Bhopal (PHED Lab) certified that the

MITHI GOBINDRAM PUBLIC SCHOOL.. (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 27-01-2027....

Signature with Seal: Chudamani Kalele.....

Name :

Designation :

Name & Address of the Office / Department :

CHUDAMANIKALELE
Chief Chemist
State Research Laboratory
P.H. Eng. Dept. Bhopal

To MITHI GOBINDRAM PUBLIC SCHOOL
Sant Hirdaram Nagar, Bhopal 462030
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

ULR No.

TC	1	6	4	2	1	2	6	0	0	0	0	0	0	7	5	0	F
----	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

Test Report

Nature of sample :- Drinking Water Sample / Others		Not sampled by State Research Lab		Unique Identification No.		644			
Sender's name and address To, MITHI GOBINDRAM PUBLIC SCHOOL LAKE ROAD SANT HIRDARAM NAGAR BHOPAL		Sender's letter no.		-		Sender's letter Date		28/01/26 /	
		SRL Ref. No		842 /		SRL receipt date		28/01/26 /	
		Date of analysis started		28/01/26 /		Date of analysis completed		30/01/26 /	
		Quantity Of sample		Ok /					

Sample details

No.	Particulars of Samples
1.	R.O WATER SAMPLE

RESULTS

Field..	Testing	Discipline..Chemical	test methods	Group..Water		Sub. Group..Drinking Water				
				BIS -10500:2012 Reaffirmed in Sep 2022		Results				
				Desirable Limit	Permissible Limit	1	2	3	4	5
1	2	3	4	5	1	2	3	4	5	
1	Colour in Hazen scale	-	5	15	BDL	-	-	-	-	-
2	Nitrate as NO3 mg/l	APHA 24 th edition,4500 NO ₃ -B	45	45	19.30	-	-	-	-	-
3	Fluoride as F mg/l	APHA 24 th edition,4500-F-C	1.0	1.5	0.18	-	-	-	-	-
4	Chloride as Cl mg/l	APHA 24 th edition,4500 Cl-B	250	1000	60.0	-	-	-	-	-
5	Total Alkalinity as CaCO ₃ mg/l	APHA 24 th edition, 2320 B	200	600	200	-	-	-	-	-
6	Calcium as Ca++ mg/l	APHA 24 th edition, 3500 Ca-B	75	200	48.8	-	-	-	-	-
7	Magnesium as Mg++ mg/l	APHA 24 th edition, 3500 Mg-	30	100	21.60	-	-	-	-	-
8	Sulphate as SO4 mg/l	BIS:3025 (Part -24)	200	400	29.97	-	-	-	-	-
9	pH pH Value at 25°C	APHA 24 th edition 4500-H + B	6.5 to 8.5	6.5 to 8.5	7.42	-	-	-	-	-
10	Turbidity in NTU	APHA 24 th edition, 2130 B	1.0	5.0	1.56	-	-	-	-	-
11	Total hardness as CaCO ₃ mg/l	APHA 24 th edition, 2340 C	200	600	212	-	-	-	-	-
12	Conductivity at 25°C (S/m)	APHA 24 th edition, 2510 B	-	-	676	-	-	-	-	-
13	TDS By meter mg/l	APHA 24 th edition,2510 B	500	2000	398	-	-	-	-	-

1. This report should not be produced partly or full without approval of signatory authority for legal purposes.-
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" in column 4, above which the sources will have to be rejected.
3. The results refer only to tested samples and parameters tested
4. Samples will be stored for a period of 15 days from the date of issue of report.
5. This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.

[Signature]
Reviewed by

[Signature]
(Chudamani Kalele)
Chief Chemist
STATE RESEARCH LABORATORY
P. H. E. DEPARTMENT BHOPAL

Issue No. 895 /S.R.L./PHED/BPL /2026 Issue Date 30/1/26

Test Report

Nature of sample :- Drinking Water Sample / Others	Not sampled by State Research Lab	Unique Identification No.	644-A ✓
Sender's name and address To, MITHI GOBINDRAM PUBLIC SCHOOL LAKE ROAD SANT HIRDARAM NAGAR BHOPAL	Sender's letter no.	-	Sender's letter Date
	SRL Ref. No	842 ✓	SRL receipt date
	Date of analysis started	28/01/26	Date of analysis completed
	Quantity Of sample	Ok	
			28/01/26 ✓
			30/01/26 ✓

Sample details

No.	Particulars of Samples
1.	R.O WATER SAMPLE

RESULTS

Field..	Testing	Discipline..Chemical	Group..Water	Sub. Group..Drinking Water					
No.	Characteristics/ Unit	test methods	BIS -10500:2012 Reaffirmed in Sep 2022		Results				
			Desirable Limit	Permissible Limit	1	2	3	4	5
1	2	3	4	5					
1	Temperature in degree C	-	-	-	25°C	-	-	-	-
2	Iron as Fe mg/l	APHA 24 th edition, 3500-Fe B	1.0	No Relaxation	1.08	-	-	-	-
3	Manganese as Mg/l	Mn APHA 24 th edition 3500-mn-B	0.1	0.3	BDL	-	-	-	-
4	Odour	-	Objectionable	Unobjectionable	-	-	-	-	-
5	Phenolphthalein Alkalinity as caCO3mg/l	APHA 24 th edition, 2320 B	-	-	-	-	-	-	-
6	Sodium as Na mg/l	APHA 24 th edition, 3500 -Na B	-	-	-	-	-	-	-
7	Potassium as K mg/l	APHA 24 th edition, 3500 -K B	-	-	-	-	-	-	-
8	Dissolved Oxygen mg/l	-	-	-	-	-	-	-	-
9	Chemical Oxygen Demand (COD)mg/l	-	-	-	-	-	-	-	-
10	Biological Oxygen Demand (BOD) mg/l	-	-	-	-	-	-	-	-
11	Jar Test for Alum & lime dosing fixation mg/l	-	-	-	-	-	-	-	-
12	Purity of Alum	-	-	-	-	-	-	-	-
13	Purity of Lime	-	-	-	-	-	-	-	-
14	Purity of Bleaching	-	-	-	-	-	-	-	-
15	Chlorine test Demand	-	-	-	-	-	-	-	-
16	Ecoli	APHA 24 th edition, 9223 B	NIL	NIL	NIL ✓	-	-	-	-
17	Total coliform per 100 ml	APHA 24 th edition, 9223 B	NIL for treated water and water in distribution system	NIL	-	-	-	-	-

1. This report should not be produced partly or full without approval of signatory authority for legal purposes.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" in column 4, above which the sources will have to be rejected.
3. The results refer only to tested samples and parameters tested
4. Samples will be stored for a period of 15 days from the date of issue of report.
5. This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.
6. This report show only Non NABL parameters.

Amr
Reviewed by

Chudamani kalele
(Chudamani kalele)
Chief Chemist
STATE RESEARCH LABORATORY
P. H. E. DEPARTMENT BHOPAL

Issue No. 895 /S.R.L./PHED/BPL /2026 Issue Date 30/1/26